

Application of Energy Efficient Technologies in Wastewater Treatment Facilities

Ahmad R. Ganji, Ph.D., P.E.
Sandra A. Chow, P.E., C.E.M.
BASE Energy, Inc.
San Francisco, CA



Stephen Fok, P.E.
Pacific Gas and Electric Company
San Francisco, CA

Industrial Energy Technology Conference 2009
New Orleans, LA
May 12 - 15, 2009



Outline

- Introduction
- Energy Efficiency, Demand Response and Other Energy System Opportunities in Wastewater Treatment Plants (WWTPs)
 - Retrofit Projects
 - New Construction and Expansion Projects
- Case Study – Retrofit Project
- Case Study – Expansion Project
- Benchmarking
- Concluding Remarks





Wastewater Treatment Plant Energy Consumption

- Wastewater treatment plants (WWTP) are one of the most energy intensive facilities managed by the public sector.
- Over 16,000 WWTP exist in the United States
 - Consumes ~3% of the nations' electrical power
- According to a 1993 study by Burton Environmental Engineering, wastewater treatment plants consume close to 1% of the electrical power in Northern and Central California




BASE

Common Wastewater Treatment Methods

- Activated Sludge
 - Most common
 - Most energy intensive
- Oxidation Ditch, Extended Aeration
- Fixed Film Reactors (Trickling Filters, Rotating Biological Contactors)
- Evaporation Ponds

Least energy intensive



BASE

Common Levels of Treatment

- Preliminary
 - Screening and grit removal
- Primary
 - Removal of a portion of the suspended solids and organic matter from wastewater
- Secondary
 - Removal of biodegradable organic matter and suspended solids
 - Also a part of this treatment is disinfection – destroys remaining microorganisms remaining in the wastewater
 - Secondary treatment usually is the most energy intensive and accounts for 30% to 60% of the total plant energy consumption
- Tertiary
 - Removal of residual suspended solids and nutrient removal
- Sludge Treatment and Disposal
 - Thickening, conditioning, stabilizing, dewatering and drying sludge prior to disposal



BASE



Energy Efficiency, Demand Response and Other Energy System Opportunities

Energy Efficiency Measures from Integrated Energy Audits

Energy Efficiency Measure	Municipal WWTFA	Municipal WWTFB	Municipal WWTFC	Municipal WWTFD	Municipal WWTFE	Municipal WWTFF	Municipal WWTFG	Municipal WWTFH	Municipal WWTFI	Municipal WWTFJ
Premium Efficiency Motors		x	x	x	x	x			x	x
Automated Dissolved Oxygen Control	x		x			x	x	x	x	x
Fine Bubble Diffusers	x									
High Efficiency Air Compressor		x								
Lighting Control	x	x	x					x		
High Efficiency Lighting			x	x				x		
Variable Frequency Drives on Blowers	x							x		x
Variable Frequency Drives on Pumps		x	x	x	x	x	x	x	x	
Variable Frequency Drives on Mechanical Aerators			x		x	x			x	x

Public Gas and Electric Company
WE BELIEVE ENERGY

BASE

Demand Response Measures from Integrated Energy Audits

Demand Response Measure	Municipal WWTFA	Municipal WWTFB	Municipal WWTFC	Municipal WWTFD	Municipal WWTFE	Municipal WWTFF	Municipal WWTFG	Municipal WWTFH	Municipal WWTFI	Municipal WWTFJ
Install Variable Frequency Drives on Pumps and Reduce Speed During Demand Response (DR) Event					x			x		
Install Variable Frequency Drives on Aerators and Reduce Speed During DR Event			x		x					
Turn Off Pumps for Duration of DR Event		x				x			x	
Turn Off Aerators for Duration of DR Event				x					x	x
Utilize Equalization Tank and Shift Pump Operation During DR Event		x								
Over-Aerate Basins/Digesters and Reduce Flow of Blowers During DR Event	x							x		
Delay Operation of Sludge Dewatering / Thickening Equipment During DR Event	x							x		x
Turn Off Blowers for Odor Removal for Duration of DR Event		x								

Public Gas and Electric Company
WE BELIEVE ENERGY

BASE

Other Energy System Opportunities from Integrated Energy Audits

Energy System Opportunity	Municipal WWTP A	Municipal WWTP B	Municipal WWTP C	Municipal WWTP D	Municipal WWTP E	Municipal WWTP F	Municipal WWTP G	Municipal WWTP H	Municipal WWTP I
Install an Anaerobic Digester and Combined Heat and Power System	x								
Install a Combined Heat and Power System		x							x
Install a Photovoltaic System					x				
Shift Aeration to Off-Peak Periods								x	
Shift Irrigation Pumping to Off-Peak Periods									x

BASE

Total Energy Savings from Integrated Energy Audits


Plant	Average Flow	% Energy Savings Identified
Municipal WWTP A	3.87 MGD	33%
Municipal WWTP B	7.5 MGD average; 12.6 MGD max.	8%
Municipal WWTP C	3.14 MGD	5%
Municipal WWTP D	1.1 MGD	5%
Municipal WWTP E	2.4 MGD	18%
Municipal WWTP F	Not Available	8%
Municipal WWTP G	7.0 MGD average; 30 MGD max	19%
Municipal WWTP H	Not Available	16%
Municipal WWTP I	1.96 MGD	21%

BASE

Energy Efficiency Measures for New Construction/Expansion Projects

Energy Efficiency Measure	Winery A WWTP	Winery B WWTP	Municipal WWTP 1	Municipal WWTP 2	Municipal WWTP 3	Municipal WWTP 4	Municipal WWTP 5	Municipal WWTP 6	Municipal WWTP 7
Premium Efficiency Motors	x	x	x	x	x	x	x	x	x
Automated Dissolved Oxygen Control	x	x	x	x	x	x	x	x	x
High Efficiency Blowers			x	x		x			
High Efficiency Aerators									x
Fine Bubble Diffusers		x	x	x		x			
High Efficiency Dewatering System		x			x	x			x
Low Pressure Ultraviolet Disinfection					x	x	x	x	
High Efficiency Pumps	x				x	x	x	x	x
Variable Frequency Drive Applications (Pumps, Aerators, Blowers, etc.)	x		x	x	x	x	x	x	x
High Efficiency Lighting			x		x				
High Efficiency HVAC			x	x	x	x			x

BASE





Case Study: Retrofit Project


Background

BASE performed an integrated energy audit for a wastewater treatment plant in Central California. The facility used an aerobic activated sludge system which included primary and secondary treatment.

Annual Electrical Energy Consumption = 9,912,000 kWh/yr
 Average Maximum Electrical Demand= 1,520 kW


Average Plant Flow = 4 MGD




Case Study: Retrofit Project (cont'd) Energy Efficiency Recommendations

Energy Efficiency Measure	Electrical Energy Savings (kWh/yr)	Demand Savings (kW)	Potential Savings (\$/yr)	Implem. Cost (\$)	Simple Payback (years)
1. Install Lighting Controllers throughout the Facility	8,113	3.0	1,100	1,948	1.8
2. Install Automated Dissolved Oxygen Control System and Variable Frequency Drives on Aeration Basin Blowers	604,176	69.0	57,767	150,250	2.7
3. Install Variable Frequency Drives on Aerobic Digester Blowers	1,788,771	204.2	170,169	174,750	1.0
4. Install Higher Efficiency Fine Bubble Diffusers	862,506	98.5	82,051	400,000	4.9
Total Energy Savings	3,263,566 kWh/yr				
Total Demand Savings		374.7 kW			
Total Cost Savings			\$308,087/yr		
Total Implementation Cost				\$726,948	
Simple Payback Period					2.4 years

 **BASE**


Case Study: Retrofit Project (cont'd) Demand Response Recommendations

Demand Response Measure	Demand Reduction (kW)	Potential Energy Credit (\$/yr)	Implem. Cost (\$)	Simple Payback (years)
1. Over-Aerate Aeration Digesters and Reduce Flow of Aeration Blowers During Demand Response Events	130.3	1,625	0	Immediate
2. Delay Operation of Centrifuge Systems During Demand Response Events	160.7	2,006	0	Immediate
3. Over-Aerate Aeration Basin No. 3 and Reduce Flow of Blowers During Demand Response Events	187.7	2,342	0	Immediate
Totals	478.7	5,973	0	0

 **BASE**

Case Study: Retrofit Project (cont'd) Other Energy System Recommendation


Other Energy System Opportunity	Potential Energy Conserved	Demand Savings	Potential Cost Savings	Potential Incentive	Implem. Cost	Simple Payback
1. Install Anaerobic Digesters and a Combined Heat and Power System	5,665,175 kWh/yr	646.7 kW	\$498,260/yr	\$144,000	\$8,956,000	18 years

 **BASE**

Case Study: Retrofit Project (cont'd)

Additional Energy Efficiency Recommendations

- Install Higher Efficiency Lighting
- Repair Compressed Air Leaks
- Install a Diffused Air Aeration System in Older Aeration Basin
- Install a Supervisory Control and Data Acquisition (SCADA) System
- Install Variable Frequency Drives on Effluent Pumps
- Install Higher Efficiency Aeration Blowers
- Install a Photovoltaic System



WE DELIVER ENERGY

BASE

Case Study: Retrofit Project (cont'd)

Summary of Energy Savings


- Total Electrical Energy Savings: 3,263,566 kWh/yr
(~33% energy savings!!)
- Demand Reduction: 375 kW
- Energy Cost Savings: \$308,087/yr

Without Incentives

- Total Incremental Costs: \$726,948
- Payback Period: 2.4 years

With Incentives

- Potential Incentives: \$205,115
- Total Incremental Costs: \$521,833
- Payback Period: 1.7 years




WE DELIVER ENERGY

BASE

Case Study: Retrofit Project (cont'd)

Implementation Results

- Energy Efficiency Measures (4 recommendations)
 - Facility plans on implementing all of the recommended measures and are in the process of trying to acquire funding for the projects
- Demand Response Measures (3 recommendations)
 - Facility does not plan on pursuing any demand response measures at this point
- Other Energy System Opportunity (1 recommendation)
 - Facility is investigating further into implementation of this measure



WE DELIVER ENERGY

BASE



Case Study: Design Review of Expansion Project

Background
Expansion and upgrade of a conventional activated sludge WWT plant in California from 16 MGD to 32 MGD.

Major Energy Consuming Equipment

- Various Wastewater Pumps (*Influent, Sludge, Return Activated Sludge, Waste Activated Sludge, Effluent, etc.*)
- Centrifuge for Sludge Dewatering
- Aeration Blowers

Pacific Gas and Electric Company
WE DELIVER ENERGY **BASE**

Case Study: Design Review (cont'd) Energy Efficiency Measures


Energy Efficiency Measure	Baseline	Energy Savings (kWh/yr)	Demand Reduction (kW)	Energy Cost Savings (\$/yr)	Incram. Cost (\$)	Potential Incentive (\$)	Payback Period (yr)
1. High Efficiency HVAC Units	CA Title 24 (Appliance Efficiency Regulations)	20,939	9.6	2,513	17,500	2,931	5.8
2. High Efficiency Lighting	CA Title 24 (Area Category Method)	104,588	12.8	12,551	0	5,229	0
3. Premium Efficiency Motors	2005 CA Title 20 Standard Motors	123,869	16.5	14,864	100,087	9,909	6.1
4. Variable Frequency Drives (VFDs) on Centrifuges	Constant Speed Centrifuge	159,323	72.8	19,119	96,313	12,746	4.4
5. Automatic DO System & VFDs on Aeration Blowers	Manual Control DO System w/ Blowers Controlled On/Off	945,157	108	113,539	159,750	75,693	0.7
6. Control Pumping Flow with VFDs	Pumps Operate On/Off at Rated Speed	844,007	264.3	101,281	353,750	67,521	2.8
7. Fine Bubble Diffusers	Coarse Bubble Diffusers	2,437,104	278.2	292,452	650,000	194,968	1.6

Pacific Gas and Electric Company
WE DELIVER ENERGY **BASE**


Case Study: Design Review (cont'd)

Summary of Energy Savings


- Total Electrical Energy Savings: 4,635,987 kWh/yr
- Demand Reduction: 762 kW
- Energy Cost Savings: \$556,319/yr
(assumed \$0.12/kWh)
- **Without Incentives**
 - Total Incremental Costs: \$1,377,400
 - Payback Period: 2.5 years
- **With Incentives**
 - Potential Incentives: \$368,997
 - Total Incremental Costs: \$521,833
 - Payback Period: 1.8 years



BASE




Benchmarking



BASE

Benchmarking WWTPs



- U.S. Environmental Protection Agency has designed an internet-based benchmarking tool called ENERGY STAR Portfolio Manager for benchmarking municipal wastewater treatment facilities.
- Calculates weather normalized energy intensity (kWh/MGD) for WWTPs based on user-specified data, which includes:
 - Location of plant
 - 12 months of energy data
 - Plant design flow rate (million gallons per day)
 - Average influent flow (million gallons per day)
 - Average influent and effluent biological oxygen demand (mg/l)
 - Whether trickle filtration is present
 - Whether nutrient removal is a part of process
- Scores plants on a scale of 1 to 100 – the higher the score the more efficient the plant is compared to other similar size plants in nation



BASE

Benchmarking WWTPs (cont'd)



- Benchmark best applied to WWTPs 150 MGD or smaller.
- Tool is based on survey of 257 plants by the American Waterworks Association Research Foundation
- Limitations of benchmark include:
 - Does not ask if plant is aerobic or anaerobic
 - Level of wastewater treatment
 - Major type of influent that is processed (industrial, residential, food processing, etc.)
 - Whether any on-site electricity generation is present





Barriers to Implementing Energy Efficiency Measures

- Meeting regulatory requirements is priority
- Capital investment to implement energy efficient projects
- Funding for projects must be approved by governing board
- Unaware of newer energy efficient technologies available
- Newer energy efficient technologies must be proven to operate effectively
- If process is working, hesitant to change process



Some Concluding Remarks

- Significant opportunities exist in wastewater treatment plants – retrofits, expansion or new construction
- According to the 2000 EPRI market assessment study, it is estimated that energy savings ranging from 20% to 40% are possible for the WWT industry
- Many programs are available to assist WWTP in implementing energy efficiency projects



Contact Information

For more information please contact:

Stephen Fok (Supervisor, Program Engineer, P.E.)
Pacific Gas & Electric Company (PG&E)
E-mail: skf2@pge.com

Sandra Chow (Senior Engineer, P.E., C.E.M.)
BASE Energy, Inc.
E-mail: schow@baseco.com



Thank You!